

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

## TEST REPORT

Client : Australian Select Timbers Pty Ltd 136 Atlas Boulevard Dandenong South VIC 3175

 Test Number
 :
 24-001525

 Issue Date
 :
 22/05/2024

 Print Date
 :
 22/05/2024

Sample Description	Clients Ref : "Australian Select Timbers 2.5mm Vinyl Plank" Vinyl flooring planks
	Colour : Timber look End Use : Flooring
	Nominal Composition : PVC, Limestone
	Nominal Mass per Unit Area/Density : 1843kg/m3
	Nominal Thickness : 2.5mm



321936

70421

C Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

Deld

Fiona McDonald



Page 1 of 2

IIOHAEL A. JACKSON B.Sc.(Hons)



Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

## TEST REPORT

Client : Australian Select Timbers Pty Ltd 136 Atlas Boulevard Dandenong South VIC 3175

Test Number	:	24-001525		
Issue Date	:	22/05/2024		
Print Date	:	22/05/2024		

AS ISO 9239.1-2003

## Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source

Date of Sample Arrival	01-05-2024					
Date Tested	22-05-2024					
CHF Value	1	2	3	Mean		
Length	9.6	-	-	-	kW/m²	
Width	9.4	9.6	9.6	9.5	kW/m²	
Smoke Value	1	2	3	Mean		
Length	129	-	-	-	%.min	
Width	144	132	150	142	%.min	
Observation						
Blistering				Yes		

Each specimen was adhered to a substrate of 6mm thick fibre reinforced cement board using Roberts 656 adhesive and clamped prior to testing.

HF30 not reported as flame out time occurred before 30 minutes.

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2010 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Results in accordance with section 8.4 have not been included in the report. They are available upon request.

321936

70421

C Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



Page 2 of 2

MICHAEL A. JACKSON B.Sc.(Hons)

Fiona McDonald APPROVED SIGNATORY