

Emission Test Certificate

Friday 10th May 2024

Supplier: Australian Select Timber Pty Ltd (136 Atlas Boulevard, Dandenong South, VIC, 3175, Australia).

Product name: LVT Symphony 2.5mm Vinyl Plank

Date Tested: 17th May 2024 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hrs):

Green Building Council of Australia Green Star Design & As Built V1.3 - 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B	LVT Symphony 2.5mm Vinyl Plank
Total Volatile Organic Compound Emission Rate Limit: <0.500 mg/m ² /hr	Total Volatile Organic Compound Emission Rate: 0.078 mg/m ² /hr
Formaldehyde Emission Rate Limit: <0.100 mg/m ² /hr	Formaldehyde Emission Rate: 0.004 mg/m ² /hr

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Travis Hale
BSc (Biotechnology)
Consultant

Tuan Duong
B.Eng. (Chemical)
Consultant